

The Public Health and Safety Organization

## **NSF Product and Service Listings**

These NSF Official Listings are current as of **Wednesday**, **July 19**, **2023** at 12:15 a.m. Eastern Time. Please <u>contact NSF</u> to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

http://info.nsf.org/Certified/PwsChemicals/Listings.asp?Company=Co250997&Standard=060&

## NSF/ANSI/CAN 60 Drinking Water Treatment Chemicals - Health Effects

## Aris Industrial S.A.

Industrial No. 491 Lima 511 Peru 511 336 5428

Visit this company's website (http://www.aris.com.pe)

Facility: Lima, Peru

Aluminum Sulfate[AL]

Trade DesignationProduct FunctionMax UseSulfato de Aluminio Granulado Tipo A PANTERA Coagulation & Flocculation180mg/L

[AL] Based on an evaluation of health effects data, the level of aluminum in the finished drinking water shall not exceed 2 mg/L.

Ferric Sulfate

Trade DesignationProduct FunctionMax UseSulfato Férrico en Solución PanteraCoagulation & Flocculation250mg/L

Number of matching Manufacturers is 1 Number of matching Products is 2

Processing time was o seconds